

ADDENDUM NO. 1

CITY OF ROCHESTER, NEW HAMPSHIRE

BID #16-32 Water Treatment Plant Security Fence, Gates and Guardrails

This addendum amends and/or supplements the bid documents as indicated below. Only these items alter the Bid Documents.

This addendum may also be obtained from City of Rochester's web site: www.rockesternh.net or will be available by request via e-mail at the following address: purchasing@rockesternh.net

Addendum is also available by written requests addressed as follows:

Bid # 16-32 Water Treatment Plant Security Fence, Gates, and Guardrails

City of Rochester, New Hampshire

31 Wakefield St.

Rochester, NH 03867

Attn: Purchasing Agent

CLARIFICATIONS AS FOLLOWS:

1. **Bid Proposal Form Revision-** In the scope of work on page 2 the following revisions reply.
 1. The Contractor will leave recyclable metal aside in an area designated by the City of Rochester. All other material will be disposed of by the contractor.
 2. The quotation should be lump sum.
 3. The guardrail posts shall be wood posts.
 4. The rails shall be galvanized steel.
 5. The end treatment used for the rails should be half rounded ends.