

City of Rochester, NH


Bid No. 17-18



Colonial Pines Sewer -  
Spaulding Turnpike Crossing

ADDENDUM No. 1

September 19, 2016



**Brown AND Caldwell** :

**COLONIAL PINES SEWER – SPAULDING TURNPIKE CROSSING**

**BID NO. 17-18**

**ROCHESTER, NH**

**ADDENDUM NO. 1**

**September 19, 2016**

\*\*\*\*\*

To be considered as part of the contract drawings and specifications for the Colonial Pines Sewer – Spaulding Turnpike Crossing Project.

---

**BIDDER QUESTIONS**

- Q1. Item #19C on page C-410-6 is an allowance item of 1. The unit price supplied is \$10,000. The extended price is \$5,000. Please clarify.
- A1. An updated Bid Form Section C-410 and Measurement and Payment Section 01025 will be issued in Addendum No. 2.

---

**SPECIFICATIONS**

**SECTION C-111**

**DELETE** “Thursday September 22, 2016” in the first paragraph and **REPLACE** with “**Thursday, October 6, 2016**”.

**DELETE** “Thursday September 14, 2016” in the first paragraph and **REPLACE** with “**Wednesday, September 28, 2016**”.

**DRAWINGS**

**DRAWING G-001**

**INSERT** the following to General Civil Notes:

“10. The Contractor shall coordinate Work with Utilil.”

**DRAWING C-101, DETAIL B**

**INSERT** the following note:

“3. Exterior Sealing Bands conforming to ASTM C-877 shall be installed at the joint of each structure.”

**END OF ADDENDUM 1**

BY ORDER CITY OF ROCHESTER, NH